



**DIVISION OF
ADMINISTRATION**
Public Health Laboratory

615 East Fourth Street
Pierre, South Dakota 57501-1700
605/773-3368 FAX: 605/773-6129
www.state.sd.us/doh/lab/index.htm

* Page 1 of 1*
Date: 8/9/2019

Submitter copy to:

BRANDON, CITY OF-0048
304 MAIN ST
PO BOX 95
BRANDON, SD 57005

Spec #: E19EC004103
Subm #:
Lab: ENV CHEMISTRY
Tel #: (605) 773-3368

Source
BRANDON/CITY WATER

Date Rcvd: 6/27/2019
Time Rcvd: 0707
Date Coll: 6/26/2019
Time Coll: 0730
Spec Type: WATER
Coll By: DALE

Preserved: AA 06-27-19 RR 0810
Remarks: NON-COMPLIANT
Source Sampled: WELL
Tap Location: ENTRY POINT SYSTEM
Type of Sample: TREATED

Final Results

Gross Alpha	5.4 +/-1.0 pCi/L
EPA 900.0 radium-228	<1.0 +/-0.3 pCi/L
Radium-226	<1.0 +/- 0.02 pCi/L